

**GOVERNMENT OF TELANGANA  
ROADS AND BUILDINGS DEPARTMENT**

From  
Sri.I.Ramesh., M.E.,  
Executive Engineer (R&B)  
Division, Nizamabad.

To  
The Principal,  
St. Ann's English Medium,  
School, Perkit(V) Armoor(M)  
District : Nizamabad.

**Lr No DB/T4/Structural Soundness /2022-23/1210 Dt:11-11-2022.**

Sir,

**Sub:-** (R&B) Dept. -Structural Soundness - St. Ann's English Medium school, H.No. 1-8-8/2 in Survey No.470/A, Armoor -Submission of Inspection - Report-Reg.

**Ref:-** 1) The Principal, St. Ann's E/M school Armoor Application Dt:02-11-2022  
2) Dy. EE/Armoor/Soundness/St. ann's school/2022-23/109  
Dt:01-11-2022.

@@N@@

The Dy. Executive Engineer (R&B) Sub-Division, Armoor vide reference 2<sup>nd</sup> cited, reported that the St. Ann's English Medium School bearing H.No.1-18/8/2 in survey No.470/A, is in perkit village and is of (G+2) Floor structure made up of RCC slabs supported on RCC columns with brick masonry walls bonded with cement mortar. In Physical observation of the building it is observed that there are no cracks and no dampness / leakages are observed in the walls, RCC slab and other parts of the building. The building structure is in good condition and it is reported that the above school building is fit for occupation and soundness the above building may be issued for one year 2022-23 (out lined map may be enclosed with mark of green outline )

The Geo Co-ordinates of the Building are:-

Latitude -18°- 47'-27" N

Longitude -78°-17'-51" E

Yours faithfully,

  
Executive Engineer (R&B)  
Division, Nizamabad

Copy to the Dy Executive Engineer(R&B) Sub-Division, Armoor for information.